



# STANDARDSMARK LICENCE

SAI Global hereby grants:

## AVK Australia Holding Pty Ltd

ABN 11 081 236 777

559A Grand Junction Road, Wingfield, SA 5013, Australia

### StandardsMark Licence

Manufactured to:

**AS/NZS 2638.2:2011 - Gate valves for waterworks purposes - Resilient seated**

**& AS/NZS 2638.1:2011 - Gate valves for waterworks purposes - Metal seated**

"the StandardsMark Licensee" the right to use the STANDARDSMARK as shown below only in respect of the goods described and detailed in the Schedule which are produced by the Licensee or on behalf of the Licensee\* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the STANDARDSMARK and the Terms and Conditions for certification and licence. The Licensee covenants to comply with all the Rules and Terms and Conditions.

**Licence No:** SMK02420

**Issued :** 6 October 2020

**Expires :** 9 December 2024

**Originally Certified :** 9 May 2000

**Current Certification :** 6 October 2020

Heather Mahon  
General Manager Technical Services  
SAI Global Assurance



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to [www.saiglobal.com](http://www.saiglobal.com), for the list of product models.



# SCHEDULE TO STANDARDSMARK LICENCE

SAI Global hereby grants:

## AVK Australia Holding Pty Ltd

559A Grand Junction Road, Wingfield, SA 5013, Australia

StandardsMark Licence

Manufactured to:

**AS/NZS 2638.1:2011 - Gate valves for waterworks purposes - Metal seated**

Model identification of the goods on which the STANDARDSMARK may be used:

Model Identification	Brand Name	Nominal Size	Product Description	Product Type	Valve class (Allowable operating Pressure)	Max Operating Temperature	End Connection Designation	Date Endorsed
2580/90 2580/92 2580/98	Sureflow	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
2580/90 2580/92 2580/98	Sureflow	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
2580/90 2580/92 2580/98	Sureflow	DN 300	DN300 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
2580/90 2580/92 2580/98	Sureflow	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
2580/90 2580/92 2580/98	Sureflow	DN 080	DN080 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
2580/90 2580/92 2580/98	Sureflow	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
2580/90 2580/92 2580/98	Sureflow	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 300	DN300 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 080	DN080 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
580/90 580/92 580/98	AVK	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	70°C	Flange x Flange	17 Jul 2019
A0412/2-039 DN100	AVK	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
A0412/2-040 DN150	AVK	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
A0412/2-041 DN200	AVK	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
A0412/2-042 DN225	AVK	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
A0412/2-043 DN250	AVK	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
A0412/2-044 DN100	AVK	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Spigot x Spigot	12 Feb 2019
A0412/2-045 DN150	AVK	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Spigot x Spigot	12 Feb 2019
A0412/2-046 DN80	AVK	DN 80	DN80 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-047 DN100	AVK	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-048 DN150	AVK	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-049 DN200	AVK	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-050 DN225	AVK	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-051 DN250	AVK	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-052 DN300	AVK	DN 300	DN300 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-053 DN375	AVK	DN 375	DN375 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Brand Name	Nominal Size	Product Description	Product Type	Valve class (Allowable operating Pressure)	Max Operating Temperature	End Connection Designation	Date Endorsed
A0412/2-054 DN450	AVK	DN 450	DN450 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-055 DN500	AVK	DN 500	DN500 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-056 DN600	AVK	DN 600	DN600 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-057 DN750	AVK	DN 750	DN750 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-065 DN80	AVK	DN 80	DN80 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-066 DN100	AVK	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-067 DN150	AVK	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-068 DN200	AVK	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-069 DN225	AVK	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-070 DN250	AVK	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-071 DN300	AVK	DN 300	DN300 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-072 DN375	AVK	DN 375	DN375 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-073 DN450	AVK	DN 450	DN450 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-074 DN500	AVK	DN 500	DN500 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-075 DN600	AVK	DN 600	DN600 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-076 DN750	AVK	DN 750	DN750 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-078 DN100	AVK	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Victaulic x Victaulic	12 Feb 2019
A0412/2-079 DN150	AVK	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Victaulic x Victaulic	12 Feb 2019
A0412/2-095 DN375	AVK	DN 375	DN375 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-096 DN375	AVK	DN 375	DN375 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-097 DN500	AVK	DN 500	DN500 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-098 DN500	AVK	DN 500	DN500 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-099 DN600	AVK	DN 600	DN600 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-100 DN600	AVK	DN 600	DN600 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-101 DN750	AVK	DN 750	DN750 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-102 DN750	AVK	DN 750	DN750 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-103 DN450	AVK	DN 450	DN450 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-104 DN450	AVK	DN 450	DN450 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-109 DN900	AVK	DN 900	DN900 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-112 DN900	AVK	DN 900	DN900 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
A0412/2-115 DN900	AVK	DN 900	DN900 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
A0412/2-116 DN900	AVK	DN 900	DN900 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-039 DN100	Sureflow	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
S0412/2-040 DN150	Sureflow	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
S0412/2-041 DN200	Sureflow	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
S0412/2-042 DN225	Sureflow	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
S0412/2-043 DN250	Sureflow	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Socket x Socket	12 Feb 2019
S0412/2-044 DN100	Sureflow	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Spigot x Spigot	12 Feb 2019
S0412/2-045 DN150	Sureflow	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Spigot x Spigot	12 Feb 2019
S0412/2-046 DN80	Sureflow	DN 80	DN80 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-047 DN100	Sureflow	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-048 DN150	Sureflow	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-049 DN200	Sureflow	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-050 DN225	Sureflow	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-051 DN250	Sureflow	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Brand Name	Nominal Size	Product Description	Product Type	Valve class (Allowable operating Pressure)	Max Operating Temperature	End Connection Designation	Date Endorsed
S0412/2-052 DN300	Sureflow	DN 300	DN300 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-053 DN375	Sureflow	DN 375	DN375 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-054 DN450	Sureflow	DN 450	DN450 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-055 DN500	Sureflow	DN 500	DN500 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-056 DN600	Sureflow	DN 600	DN600 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-057 DN750	Sureflow	DN 750	DN750 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-065 DN80	Sureflow	DN 80	DN80 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-066 DN100	Sureflow	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-067 DN150	Sureflow	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-068 DN200	Sureflow	DN 200	DN200 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-069 DN225	Sureflow	DN 225	DN225 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-070 DN250	Sureflow	DN 250	DN250 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-071 DN300	Sureflow	DN 300	DN300 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-072 DN375	Sureflow	DN 375	DN375 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-073 DN450	Sureflow	DN 450	DN450 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-074 DN500	Sureflow	DN 500	DN500 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-075 DN600	Sureflow	DN 600	DN600 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-076 DN750	Sureflow	DN 750	DN750 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-078 DN100	Sureflow	DN 100	DN100 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Victaulic x Victaulic	12 Feb 2019
S0412/2-079 DN150	Sureflow	DN 150	DN150 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Victaulic x Victaulic	12 Feb 2019
S0412/2-095 DN375	Sureflow	DN 375	DN375 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-096 DN375	Sureflow	DN 375	DN375 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-097 DN500	Sureflow	DN 500	DN500 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-098 DN500	Sureflow	DN 500	DN500 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-099 DN600	Sureflow	DN 600	DN600 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-100 DN600	Sureflow	DN 600	DN600 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-101 DN750	Sureflow	DN 750	DN750 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-102 DN750	Sureflow	DN 750	DN750 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-103 DN450	Sureflow	DN 450	DN450 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-104 DN450	Sureflow	DN 450	DN450 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-109 DN900	Sureflow	DN 900	DN900 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-112 DN900	Sureflow	DN 900	DN900 Metal Seated Gate Valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S0412/2-115 DN900	Sureflow	DN 900	DN900 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	12 Feb 2019
S0412/2-116 DN900	Sureflow	DN 900	DN900 Metal Seated Gate Valve with Bypass valve	Metal Seated Gate Valve	35	40°C	Flange x Flange	12 Feb 2019
S2580/92-375	Sureflow	DN 375	S2580 DN375 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S2580/92-450	Sureflow	DN 450	S2580 DN450 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S2580/92-500	Sureflow	DN 500	S2580 DN500 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S2580/92-600	Sureflow	DN 600	S2580 DN600 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S2580/93-375	Sureflow	DN 375	S2580 DN375 Metal Seated Gate Valve With DN100 Bypass	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S2580/93-450	Sureflow	DN 450	S2580 DN450 Metal Seated Gate Valve With DN100 Bypass	Metal Seated Gate Valve	16	40°C	Flange x Flange Bypass	21 Aug 2020
S2580/93-500	Sureflow	DN 500	S2580 DN500 Metal Seated Gate Valve With DN150 Bypass	Metal Seated Gate Valve	16	40°C	Flange x Flange Bypass	21 Aug 2020
S2580/93-600	Sureflow	DN 600	S2580 DN600 Metal Seated Gate Valve with DN150 Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange Bypass	21 Aug 2020
S580/92-375	AVK	DN 375	S580 DN375 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S580/92-450	AVK	DN 450	S580 DN450 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.



# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Brand Name	Nominal Size	Product Description	Product Type	Valve class (Allowable operating Pressure)	Max Operating Temperature	End Connection Designation	Date Endorsed
S580/92-500	AVK	DN 500	S580 DN500 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S580/92-600	AVK	DN 600	S580 DN600 Metal Seated Gate Valve	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S580/93-375	AVK	DN 375	S580 DN375 Metal Seated Gate Valve With DN100 Bypass	Metal Seated Gate Valve	16	40°C	Flange x Flange	21 Aug 2020
S580/93-450	AVK	DN 450	S580 DN450 Metal Seated Gate Valve With DN100 Bypass	Metal Seated Gate Valve	16	40°C	Flange x Flange Bypass	21 Aug 2020
S580/93-500	AVK	DN 500	S580 DN500 Metal Seated Gate Valve With DN150 Bypass	Metal Seated Gate Valve	16	40°C	Flange x Flange Bypass	21 Aug 2020
S580/93-600	AVK	DN 600	S580 DN600 Metal Seated Gate Valve with DN150 Bypass valve	Metal Seated Gate Valve	16	40°C	Flange x Flange Bypass	21 Aug 2020

## AS/NZS 2638.2:2011 - Gate valves for waterworks purposes - Resilient seated

Model identification of the goods on which the STANDARDSMARK may be used:

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
2055/74	RSGV	Sureflow	DN500 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 500	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
2055/74	RSGV	Sureflow	DN450 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 450	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
2055/74	RSGV	Sureflow	DN600 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
2055/80	RSGV	Sureflow	DN600 Resilient Seated Gate Valve with DN150 Bypass valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
2570/50	RSGV	Sureflow	DN375 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 375	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/50	RSGV	Sureflow	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/50	RSGV	Sureflow	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/50	RSGV	Sureflow	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/50	RSGV	Sureflow	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/50	RSGV	Sureflow	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/50	RSGV	Sureflow	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017

Licence No: SMK02420

Issued Date: 6 October 2020

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICEISE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
2570/50	RSGV	Sureflow	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/50] 2/Handwheel [2570/58] 3/Gearbox [2570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
2570/60	RSGV	Sureflow	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
2570/60	RSGV	Sureflow	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
2570/60	RSGV	Sureflow	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
2570/60	RSGV	Sureflow	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN080	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
2570/60	RSGV	Sureflow	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	1 Aug 2017
2570/60	RSGV	Sureflow	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	1 Aug 2017
2570/60	RSGV	Sureflow	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/60] 2/Handwheel [2570/68] 3/Gearbox [2570/62]	Option of CC or ACC	Spigot x Spigot	1 Aug 2017
2570/70	RSGV	Sureflow	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/70] 2/Handwheel [2570/78] 3/Gearbox [2570/72]	Option of CC or ACC	Flange x Socket	1 Aug 2017
2570/70	RSGV	Sureflow	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/70] 2/Handwheel [2570/78] 3/Gearbox [2570/72]	Option of CC or ACC	Flange x Socket	1 Aug 2017
2570/70	RSGV	Sureflow	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/70] 2/Handwheel [2570/78] 3/Gearbox [2570/72]	Option of CC or ACC	Flange x Socket	1 Aug 2017
2570/90	RSGV	Sureflow	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
2570/90	RSGV	Sureflow	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
2570/90	RSGV	Sureflow	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
2570/90	RSGV	Sureflow	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
2570/90	RSGV	Sureflow	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
2570/90	RSGV	Sureflow	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
2570/90	RSGV	Sureflow	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
2570/90	RSGV	Sureflow	DN400 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 400	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
2570/90	RSGV	Sureflow	DN375 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 375	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [2570/90] 2/Handwheel [2570/98] 3/Gearbox [2570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
2570/96	RSGV	Sureflow	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
2570/96	RSGV	Sureflow	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	FlangexFlange OS&Y	20 Feb 2019
2570/96	RSGV	Sureflow	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	FlangexFlange OS&Y	20 Feb 2019
2570/96	RSGV	Sureflow	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	FlangexFlange OS&Y	20 Feb 2019
2570/96	RSGV	Sureflow	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 080	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	FlangexFlange OS&Y	20 Feb 2019
2570/96	RSGV	Sureflow	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	FlangexFlange OS&Y	20 Feb 2019
2570/96	RSGV	Sureflow	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [2570/96]	Option of CC or ACC	FlangexFlange OS&Y	20 Feb 2019
55/74	RSGV	AVK	DN600 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
55/74	RSGV	AVK	DN450 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 450	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
55/74	RSGV	AVK	DN500 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 500	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
55/80	RSGV	AVK	DN600 Resilient Seated Gate Valve with DN150 Bypass valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Aug 2017
57	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011

Licence No: SMK02420

Issued Date: 6 October 2020

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN80 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN375 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 375	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN400 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 400	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	14 Oct 2011
57	RSGV	AVK	DN80 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Spigot x Spigot	14 Oct 2011

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.



# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Socket	14 Oct 2011
57	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Spigot x Spigot	14 Oct 2011
57	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	14 Oct 2011
57	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Socket	14 Oct 2011
57	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Spigot x Spigot	14 Oct 2011
57/55	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/55	RSGV	AVK	DN80 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/55	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/55	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/55	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/55	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/55	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	14 Oct 2011
57/65	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Spigot x Spigot	14 Oct 2011

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57/75	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Socket	14 Oct 2011
57/90	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
57/90	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
57/90	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
57/90	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
57/90	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
57/90	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HUF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
570/50	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/50	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/50	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/50	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/50	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/50	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/50	RSGV	AVK	DN375 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 375	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICEISE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
570/50	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/50] 2/Handwheel [570/58] 3/Gearbox [570/52]	Option of CC or ACC	Socket x Socket	1 Aug 2017
570/60	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN080	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
570/60	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
570/60	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
570/60	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	1 Aug 2017
570/60	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	1 Aug 2017
570/60	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	22 Mar 2019
570/60	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/60] 2/Handwheel [570/68] 3/Gearbox [570/62]	Option of CC or ACC	Spigot x Spigot	1 Aug 2017
570/70	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/70] 2/Handwheel [570/78] 3/Gearbox [570/72]	Option of CC or ACC	Flange x Socket	1 Aug 2017
570/70	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/70] 2/Handwheel [570/78] 3/Gearbox [570/72]	Option of CC or ACC	Flange x Socket	1 Aug 2017
570/70	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/70] 2/Handwheel [570/78] 3/Gearbox [570/72]	Option of CC or ACC	Flange x Socket	1 Aug 2017
570/90	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
570/90	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
570/90	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
570/90	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017

**Licence No: SMK02420**

**Issued Date: 6 October 2020**

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.

# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
570/90	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
570/90	RSGV	AVK	DN375 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 375	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
570/90	RSGV	AVK	DN400 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 400	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
570/90	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	28 Feb 2017
570/90	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap [570/90] 2/Handwheel [570/98] 3/Gearbox [570/92]	Option of CC or ACC	Flange x Flange	10 Apr 2017
570/96	RSGV	AVK	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
570/96	RSGV	AVK	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
570/96	RSGV	AVK	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 080	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
570/96	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
570/96	RSGV	AVK	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
570/96	RSGV	AVK	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
570/96	RSGV	AVK	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Handwheel [570/96]	Option of CC or ACC	Flange x Flange OS&Y	20 Feb 2019
5790	RSGV	AVK	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicost R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	14 Oct 2011
S2570/42-450	S2570	Sureflow	DN450 Resilient Seated Gate Valve With DN100&DN150 Bypass	Resilient Seated Gate Valve	DN 450	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	30 Apr 2020
S2570/42-500	S2570	Sureflow	DN500 Resilient Seated Gate Valve With DN100&DN150 Bypass	Resilient Seated Gate Valve	DN 500	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	30 Apr 2020
S2570/42-600	S2570	Sureflow	DN600 Resilient Seated Gate Valve with DN100&DN150 Bypass	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	4 May 2020
S2570/42-750	S2570	Sureflow	DN750 Resilient Seated Gate Valve With DN150 Bypass	Resilient Seated Gate Valve	DN 750	16	40°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	1 Oct 2020
S2570/92-450	S2570	Sureflow	DN450 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 450	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	30 Apr 2020
S2570/92-500	S2570	Sureflow	DN500 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 500	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	30 Apr 2020
S2570/92-600	S2570	Sureflow	DN600 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	30 Apr 2020
S2570/92-750	S2570	Sureflow	DN750 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 750	16	40°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Oct 2020

Licence No: SMK02420

Issued Date: 6 October 2020

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.



# SCHEDULE TO STANDARDSMARK LICENCE

Model Identification	Model Name	Brand Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operating Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
S570/42-450	S570	AVK	DN450 Resilient Seated Gate Valve With DN100&DN150 Bypass	Resilient Seated Gate Valve	DN 450	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	30 Apr 2020
S570/42-500	S570	AVK	DN500 Resilient Seated Gate Valve With DN100&DN150 Bypass	Resilient Seated Gate Valve	DN 500	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	30 Apr 2020
S570/42-600	S570	AVK	DN600 Resilient Seated Gate Valve With DN100&DN150 Bypass valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	4 May 2020
S570/42-750	S570	AVK	DN750 Resilient Seated Gate Valve With DN100&DN150 Bypass	Resilient Seated Gate Valve	DN 750	16	40°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange Bypass	1 Oct 2020
S570/92-450	S570	AVK	DN450 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 450	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	30 Apr 2020
S570/92-500	S570	AVK	DN500 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 500	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	30 Apr 2020
S570/92-600	S570	AVK	DN600 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 600	16	70°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	30 Apr 2020
S570/92-750	S570	AVK	DN750 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 750	16	40°C	Ductile Cast Iron	Polymeric to AS 4158	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Oct 2020

**End of Record**

**Licence No:** SMK02420

**Issued Date:** 6 October 2020

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The STANDARDSMARK is a registered certification trademark of SAI Global Pty Limited (A.C.N. 050 644 642) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 680 George Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to the Schedule for the list of product models.